



SECTION AA

NOTES

1. ALL CONCRETE SHALL BE MD DEPT. OF TRANS. S.H.A. MIX NO.3 WITH A 28 DAY COMPRESSIVE STRENGTH OF 3,500 P.S.I., WITH 5%-8% AIR AND 2"-5" SLUMP. ALL EXPOSED SURFACES SHALL RECEIVE A LIGHT BROOM FINISH. DO NOT ADD WATER TO SURFACE FOR FINISHING. REFER TO PLATE T-040 FOR STANDARD CONCRETE CURB & GUTTER AND PLATE T-050 FOR STANDARD CONCRETE SIDEWALK.
2. THE FACE OF THE CURB RADIUS SHALL BE TANGENT TO THE STREET CURB FACE AND INTERSECT THE FRONT EDGE OF THE SIDEWALK AND THE EDGE OF THE ENTRANCE PAVEMENT. THE CURB RADIUS SHALL BE 5'-0" MINIMUM.



CITY OF HAGERSTOWN, MARYLAND - ENGINEERING DIVISION

TRANSPORTATION STANDARD DETAIL

RESIDENTIAL DRIVEWAY ENTRANCE WITH RADIUS CURB

(BY APPROVAL OF THE CITY ENGINEER ONLY)

ISSUE DATE: 01-25-2024	
REVISIONS	
01-02-2025	_____
_____	_____
Plate T-061	